

FOR OFFICE USE ONLY
 Facility #: 7024633
 Permit #: 00956-2026CAT
 Request Rec'd: 07/30/2026
 Approval Date: 08/13/2026 DS
 Permit Expires: 02/17/2027

Tank 2 Equipment

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

NACE Certified Designer

NACE Certified Designer Number

Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Removing cathodic protection from piping.

Boots were replaced or repaired in dispenser sumps passed after.


Sumps were dry and passed.

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
128 Millwell Drive
Maryland Heights, MO 63043

Contact Person: Terry Smith
Phone: 314/241-3767
Email: cbayne@unitedpetro.com
Contractor License # IL002402 Exp. 2/10/2028

Sincerely,



Daniel Starks