Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 6037436
Permit #: 01092-2026REM
Request Rec'd: 09/10/2026
Approval Date: 09/10/2026 DS
Permit Expires: 03/10/2027

Permit for REMOVAL of Regulated Underground Storage Tank Piping Only

Permission is hereby granted to remove the underground storage tank piping for the tank(s) identified below. All removal activities must be conducted in accordance with all applicable sections of 41 Ill. Adm. Code Parts 174, 175, and 176. The permitted contractor must schedule a date certain for the piping removal through their contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator, or designated representative must notify the Illinois Emergency Management Agency at (800)782-7860. This is to be done at the site immediately following the field determination and the incident number shall be given to the STSS prior to his/her leaving the site. All removals require a site assessment and must be performed in accordance with 35 Ill. Adm. Code 734.210(h)(1) and (2). Samples shall be taken in native soil with the excavation for the removal still open and prior to backfill and with the STSS still on site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	**FACILITY** - name and address where tanks are located:
Moto, Inc. 721 W. Main Street Belleville, IL 62222 St. Clair County Contact: Shane Maxey 618/233-6754	BAC Moto, Inc. 1920 Caryle Avenue Belleville, IL 62222 St. Clair County Contact: Rick Martin 618/222-1127

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
2	15,000	Gasoline - Premium	

Summary of Work
Only the section of premium piping from the STP sump and dispenser 3/4 will be removed from the existing chase pipe. A new section of product piping will be installed through the existing chase pipe

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2028

Sincerely,

Daniel Starks

Daniel Starks