Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2045958
Permit #: 01095-2026UPG
Request Rec'd: 09/10/2026
Approval Date: 09/10/2026 DS
Permit Expires: 03/10/2027

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	**FACILITY** - name and address where tanks are located:
County of McHenry 2200 N. Seminary Ave. Woodstock, IL 60098 McHenry County Contact: Brian Krause 815/334-4819	County of McHenry - Jail 2200 N. Seminary Avenue Woodstock, IL 60098 McHenry County Contact: Richard Rose 815/334-0105

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work
Replacing overspill manhole located in the tank sump with new double wall spill bucket.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 325 W. Highland Avenue Elgin, IL 60123	Contact Person: Robert Sumoski Phone: 630/444-7350 Email: yvonne@crownetank.com Contractor License # IL002345 Exp. 5/16/2028

Sincerely,

Daniel Starks

Daniel Starks