City of Chicago
Department of Environment
2160 W. Ogden
Chicago, IL 60612
312/617-4550
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2048069
Permit #: 01097-2026ABN
Request Rec'd: 09/10/2026
Approval Date: 09/10/2026 SK
Permit Expires: 03/10/2027

Permit for ABANDONMENT-IN-PLACE of Regulated Underground Storage Tanks and Piping

Permission is hereby granted to abandon-in-place the underground storage tank(s) or associated piping identified below. All abandonment activities must be conducted in accordance with all applicable sections of 41 Ill. Adm. Code Parts 174, 175, and 176. The permitted contractor must schedule a date certain for the UST abandonment through their contractor portal account. If the Storage Tank Safety Specialist (STSS) observes any indication of a release, the owner, operator, or designated representative must immediately notify the Illinois Emergency Management Agency at (800)782 7860. The assigned incident number must be provided to the STSS before departing the site. All abandonments require a site assessment and must be performed in accordance with 35 Ill. Adm. Code 734.210(h)(1) and (2). Samples may be taken prior to or on the day of abandonment-in-place and shall meet all the requirements in 41 Il. Adm. Code 176.330.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	**FACILITY** - name and address where tanks are located:
936 W Huron LLC 2900 W Logan Blvd Chicago, IL 60647 Contact: Michael LaPorta 312/479-2090	Vacant Retail 936 W. Huron Street Chicago, IL 60642 Cook County 17-08-212-004-0000 Contact: Michael LaPorta 312/479-2090

Tanks on the Permit
* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	1,000	Heating Oil	Inert material mixed with portland cement

Explanation of Waiver for Abandonment
Abandonment in place due to location of UST inside building. The masonry walls surrounding the tank are overlain by the floor joists.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2028

Sincerely,

Sean Keane