



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2024840
Permit #: 01119-2026UPG
Request Rec'd: 09/17/2026
Approval Date: 09/17/2026 DS
Permit Expires: 03/17/2027

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Cook County Highway Department 8900 W. 135th Street Orland Park, IL 60462 Cook County Contact: Randy Piscitelli 708/388-2134	FACILITY - name and address where tanks are located: Cook County Highway Dept Dist 1 2325 Meacham Road Schaumburg, IL 60195 Cook County Contact: Randy Piscitelli 708/397-4145
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	10,000	Currently in use	Federal
7	Gasoline - Regular	2,500	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS-4	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel i Site
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser	Removing
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS-4	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel i Site
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

Dispensers on the Permit

Dispenser	Action
1 REG	Sump and/or Sensor Changing
2 DSL	Sump and/or Sensor Changing

Dispenser 1 REG Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Dispenser 2 DSL Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New


Summary of Work

Installing new frp dispenser sumps where none previously existed with new island. Removing existing ATG and installing new TLS4, new probes, interstitial sensors and sump sensors. Remove and replace diesel tank pad.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2028

Sincerely,



Daniel Starks

For Office Use Only**Dispenser 1 REG Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

Dispenser 2 DSL Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing