Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2048078
Permit #: 01198-2026ABN
Request Rec'd: 09/25/2026
Approval Date: 09/30/2026 DS
Permit Expires: 03/30/2027

Permit for ABANDONMENT-IN-PLACE of Regulated Underground Storage Tanks and Piping

Permission is hereby granted to abandon-in-place the underground storage tank(s) or associated piping identified below. All abandonment activities must be conducted in accordance with all applicable sections of 41 Ill. Adm. Code Parts 174, 175, and 176. The permitted contractor must schedule a date certain for the UST abandonment through their contractor portal account. If the Storage Tank Safety Specialist (STSS) observes any indication of a release, the owner, operator, or designated representative must immediately notify the Illinois Emergency Management Agency at (800)782 7860. The assigned incident number must be provided to the STSS before departing the site. All abandonments require a site assessment and must be performed in accordance with 35 Ill. Adm. Code 734.210(h)(1) and (2). Samples may be taken prior to or on the day of abandonment-in-place and shall meet all the requirements in 41 Il. Adm. Code 176.330.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	**FACILITY** - name and address where tanks are located:
Burlington LLC 9645 Willow Lane Mokena, IL 60448 Contact: Anthony Laderosa 773/428-0953	Commercial Property 518-522 W Burlington Ave La Grange, IL 60525 Cook County 18-04-120-001-0000 Contact: Anthony Laderosa 773/428-0953

Tanks on the Permit
* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	2,000	#2 Fuel Oil	Inert material mixed with portland cement

Explanation of Waiver for Abandonment
Abandonment in place of one 2,000 gallon UST and associated tank piping due to location in courtyard

Location of Tanks Being Abandoned
Tank is located 5' from building foundation. Attempting to remove the tank would likely undermine the structural integrity of the building.

Location of Piping Being Abandoned
Pipin is located 5' from building foundation. Attempting to remove the piping would likely undermine the structural integrity of the building.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2028

Sincerely,

Daniel Starks