

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605 FOR OFFICE USE ONLY Facility # 2-028424 Permit # 01531-2006UPG

Request Rec'd 10/11/2006 Amended Date Approval Date 10/18/2006 DS Permit Expires 4/18/2007

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:

Exxon Mobil Oil Corporation

7300 W. Friendly Avenue, P.O. Box 22087, CMS Mailstop F-76

Greensboro, NC 27420-2087

Contact: Eric McPhee (303) 986-8011

(2) <u>FACILITY</u> - name and address where tanks are located:

Mobil Oil Corp 05Ccd 1000 N Wood Dale-Thorndale Wood Dale, Du Page Co., IL

Contact: Hanchet Karen (847) 616-1200

(3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4, 5) 10,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 1, 2, 3, 4, 5) Existing Existing steel flex connectors
- (d) Product to be stored in each tank: (TK # 1, 2, 3, 4) Gasoline, (TK # 5) Diesel Fuel
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 1, 2, 3, 4, 5) Existing Sacrificial anodes cathodic protection

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES**:

	(6)	PERSON,	FIRM	OR	COMPANY	PERFORMING	WORK:
--	------------	---------	------	----	---------	------------	-------

Contact Person:

Phone:

Daniel J. Starke

Contractor Registration # Exp

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)