

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL **Division of Technical Services**

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 1-034566 Permit # 01521-2006UPG Request Rec'd 10/05/2006 Amended Date Approval Date 10/17/2006 DS Permit Expires 4/17/2007

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Stop-N-Go , Inc 2934 Fish Hatchery Rd Madison, WI 53713	Stop N Go 527 1000 S 7Th St Rochelle, Ogle Co., IL
Contact: Lou Zinger (608) 271-4433	Contact: Lou Zinger (608) 271-4433

(3) **UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) 12,000 gallons
- (b) Type of tanks: (TK # 1) Existing Existing double wall composite
- (c) Type of piping: (TK # 1) (Installing) Steel flex connectors, (TK # 1) Existing double wall fiberglass, (TK # 1) Existing Single wall fiberglass (TK # 1) - Replacing existing flex connectors at dispensers #11 & #12
- (d) Product to be stored in each tank: (TK # 1) Gasoline
- (e) Type of leak detection being used:

Tank: (TK # 1) Existing Existing automatic tank gauging

Piping: (TK # 1) Existing Existing continuous line pressure monitor

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 1) Existing Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
	Contractor Registration #	Exp.

Daniel J. Starke

Sincerely,

Daniel Starks