



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

FOR OFFICE USE ONLY  
 Facility # 2-016490  
 Permit # 01421-2006UPG  
 Request Rec'd 09/22/2006  
 Amended Date  
 Approval Date 9/26/2006 DS  
 Permit Expires 3/26/2007

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          N &amp; P Group, Inc.          22800 W. Lincoln Hwy          Plainfield, IL 60586          Contact: Shaji Philip Edat (773) 467-5711</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Joliet I-55 Auto Truck Plaza          22800 W. Lincoln Highway          Plainfield, Will Co., IL          Contact: Jane Scott (815) 726-3831</p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 11, 12) - 20,000 gallons
- (b) **Type of tanks:** (TK # 11, 12) Existing Existing single wall fiberglass
- (c) **Type of piping:** (TK # 11, 12) Existing Existing double wall fiberglass, (TK # 11, 12) Existing Existing single wall fiberglass, (TK # 11, 12) Existing Existing single wall steel
- (d) **Product to be stored in each tank:** (TK # 11, 12) - Diesel Fuel
- (e) **Type of leak detection being used:**  
  - Tank:** (TK # 11, 12) Existing Existing automatic tank gauging
  - Piping:** (TK # 11, 12) - (Installing) Red Jacket FX1DV mechanical line leak detector, (TK # 11, 12) Existing Vaporless LD2000 mechanical line leak detector (TK # 11, 12) - Adding mechanical line leak detector to diesel product lines, which require breaking the product lines to add Red Jacket Housings for FX Detectors.
- (f) **Corrosion Protection being used:**  
  - Tank:**
  - Piping:** (TK # 11, 12) Existing Existing impressed current cathodic protection, (TK # 11, 12) Existing Existing fiberglass
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p align="right">Contact Person:          Phone:          Contractor Registration # Exp.</p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File

