



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 4-012376  
Permit # 01162-2006CAT  
Request Rec'd 08/03/2006  
Amended Date  
Approval Date 8/9/2006 DT  
Permit Expires 2/9/2007

**Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Colonial Pantry, LTD 716 South Randolph Street, P.O. Box 1004 Champaign, IL 61820 Contact: Patrick Miller (217) 352-6789	<b>(2) FACILITY</b> - name and address where tanks are located: Colonial Pantry 4 301 S Main St Gifford, Champaign Co., IL Contact: Gayle Cremons (217) 568-7637
--	--

**(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:**

- (a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 1, 2) - 6,000 gallons, (TK # 3) - 2,000 gallons, (TK # 4) - 4,000 gallons
- (b) *Type of tanks:* (TK # 1, 2, 3, 4) - Existing single wall STI P3
- (c) *Type of piping:* (TK # 1, 2, 3, 4) - Existing single wall fiberglass
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel
- (e) *Type of leak detection being used:*  
*Tank:* (TK # 1, 2, 3, 4) - Existing statistical inventory reconciliation  
*Piping:*
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 1, 2, 3, 4) - Existing fiberglass
- (g) *NACE certified designer:* *Certification number:*
- (h) *Method of integrity assessment of tank(s) being used:*

- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>
Contact Person:
Phone:
Contractor Registration #    Exp.

Sincerely,

Dale Tanke

Dale Tanke

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)