



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 7-001352
Permit # 00963-2006FLX
Request Rec'd 06/22/2006
Amended Date
Approval Date 7/6/2006 JC
Permit Expires 1/6/2007

Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Davis & Sons Oil Company, Inc. 602 W. Water Street, P.O. Box 444 Fairfield, IL 62837 Contact: Todd Davis (618) 842-9151	(2) FACILITY - name and address where tanks are located: Patty's Marathon 1416 S 10th Street Mount Vernon, Jefferson Co., IL Contact: Davis Todd (618) 842-9151
---	--

(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons, (TK # 2) - 6,000 gallons
- (b) *Type of flex connector(s):* (TK # 1, 2) - Existing steel flex connectors
- (c) *Product stored in each tank:* (TK # 1, 2) - Gasoline
- (d) *Corrosion Protection being installed with flex connector(s):* (TK # 1, 2) - (Installing) Flex connector sacrificial spike anode cathodic protection

- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

- (5) SPECIAL CONTINGENCIES:** Tanks 1 & 2 probably had impressed current installed on them from permit #3023-98 in late 1998; however, we do not have an inspector log to verify this, nor do we have a notification form with an oath signed by the contractor to verify this either (later certification audits do say that tanks 1 & 2 have impressed current). A new form of tank leak detection for tanks 1 & 2 will be due by late 2008 since the sole method of leak detection for the tanks is monthly inventory control. Also, tanks 1 & 2 were lined 06/23/00. Inspector must also make sure the owner sends in a notification form to register tanks 5 & 6 (tanks 5 & 6 have an installation log to show they were installed but no notification form to register them).

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Midwest Petroleum Service Danville, IL 61834	Contact Person: Phone: Contractor Registration # Exp.
---	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)