



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-022785
Permit # 00626-2012INS
Request Rec'd 07/02/2012
Amended Date 09/13/2012
Approval Date 7/2/2012 JC
Permit Expires 1/2/2013

Amended

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: B&R Oil Company, Inc. 24501 Ecorse Rd. Taylor, MI 48180 Contact: William Shaver	(2) FACILITY - name and address where tanks are located: BP #26262 1200 E. 75th Downers Grove, Du Page Co., IL Contact: Bradley R (630) 990-5722
---	---

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** One compartment tank consisting of the following three tanks: (TK # 8, 10) - 6,000 gallons, (TK # 9) - 20,000 gallons
- (b) **Type of tanks:** (TK # 8, 9, 10) - (Installing) Fiberglass Double Wall XERXES
- (c) **Type of piping:** (TK # 8, 9, 10) - (Installing) Fiberglass Single Wall vent Piping Ameron , (TK # 8, 9, 10) - (Installing) Fiberglass Double Wall product piping Ameron Dualoy 3000/LCX
- (d) **Product to be stored in each tank:** (TK # 8) - Diesel Fuel, (TK # 9, 10) - Gasoline
- (e) **Type of leak detection being used:**
 - Tank:** (TK # 8, 9, 10) - (Installing) Interstitial Monitoring Veeder Root TLS 350 , (TK # 8, 9, 10) - (Installing) Automatic Tank Gauging Veeder Root TLS 350
 - Piping:** (TK # 8, 9, 10) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at all dispenser sumps and at all submersible sumps , (TK # 8) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D , (TK # 9, 10) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD
- (f) **Corrosion Protection being used:**
 - Tank:** (TK # 8, 9, 10) - (Installing) Fiberglass Non-Corrosive
 - Piping:** (TK # 8, 9, 10) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping and dispenser containment devices:** (TK # 8, 9, 10) - (Installing) Manhole Pre-manufactured OPW 1
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

- (6) **SPECIAL CONTINGENCIES:** See amended site plan.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:	Contact Person: Robert Sumoski Phone: (630) 497-9009 Contractor Registration # IL-002345 Exp.
---	---

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)