



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-018386
Permit # 00846-2006TUP
Request Rec'd 06/08/2006
Amended Date
Approval Date 6/9/2006 JC
Permit Expires 12/9/2006

Permit for TOUCH-UP INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to internally line underground storage tank(s) or piping is hereby granted. Such partial interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. Such partial interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: JDN Enterprises LTD P O Box 444 Western Springs, IL 60558 Contact: Jim Gueitsman (708) 784-0100	(2) FACILITY - name and address where tanks are located: Citgo Minuteman 3419 Maple Ave Brookfield, Cook Co., IL Contact: Jim Gleitsman (708) 784-0100
---	---

(3) INTERIOR LINING OF TANKS:

- (a) Number and size of tanks being internally lined:* (TK # 2) - 6,000 gallons
- (b) Type of tanks:* (TK # 2) - Existing single wall steel
- (c) Name of manufacturer of internal lining material:* (TK # 2) Indus. Enviro. Coatings
- (d) Designation of internal lining material:* (TK # 2) EC 125
- (e) Product to be stored in each tank:* (TK # 2) - Gasoline
(Internal lining material must be compatible with product stored in each tank)
- (f) Percentage of each tank being partially lined:*
(Lining Touch-up cannot exceed 30% of entire tank)

- (4) This permit is VOID if tank is unacceptable for touch-up of interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for touch-up of interior lining only. Separate permits are required to do interior tank lining inspections or installations of manways.**
- (5) The owner must notify this Office when completion of tank internal lining touch-up has occurred, on the Notification Form for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**
- (6) SPECIAL CONTINGENCIES:** STSS must review special contingencies for permit #00525-2006FLX, #00561-2006LIN and #00845-2006REL for a complete review of this site.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: 600 Hartrey	Contact Person: Phone: Contractor Registration # Exp.
--	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)