



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 2-013815
Permit # 00963-2012UPG
Request Rec'd 09/11/2012
Amended Date
Approval Date 9/12/2012 JC
Permit Expires 3/12/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Gajanan Ford Corporation 788 Williamsburg Carol Stream, IL 60188</p> <p>Contact: Bhadrik Patel (630) 408-7909</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Rolling Meadows Marathon 4200 Kirchoff Rolling Meadows, Cook Co., IL</p> <p>Contact: Tyrone Brown (847) 991-0400</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) **Number and size of tanks being upgraded or repaired:** (TK # 1, 2) - 10,000 gallons (tank #1 is converting from gasoline to diesel).

(b) **Type of tanks:**

(c) **Type of piping:** (TK # 1, 2) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from the submersible pump of tank #1 to dispenser # 11/12. Also, the existing regular unleaded gasoline lines (from tanks 1 and 2) will be manifolded together near the submersible sump for tank #2 only - a very short localized section of piping from the submersible pump at tank #1 is allowed to be removed from this area to accommodate this action.

(d) **Product to be stored in each tank:** (TK # 1, 2) - Gasoline

(e) **Type of leak detection being used:**

Tank:

Piping: (TK # 1) - (Installing) Stand Alone Sensor Interstitial Monitoring Veeder Root TLS 350 non-discriminating at dispenser # 11/12 only, (TK # 1) - (Installing) Piping Sump Sensor Interstitial Monitoring Veeder Root TLS 350 at the submersible sump only.

(f) **Corrosion Protection being used:**

Tank:

Piping: (TK # 1, 2) - (Installing) Fiberglass Non-Corrosive

(g) **Spill containment devices, piping, and dispenser containment devices:**

(h) **Overfill prevention devices:**

(i) **Manway accessible at grade:**

(4) **The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES: Tank #1 is converting from gasoline to diesel.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Lansing, IL 60438</p>	<p>Contact Person: Ed Angell Phone: (708) 474-3344</p> <p>Contractor Registration # IL-1207 Exp.</p>
---	---

Sincerely,

