



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 5-020614
Permit # 00764-2006LIN
Request Rec'd 05/24/2006
Amended Date
Approval Date 5/30/2006 JC
Permit Expires 11/30/2006

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Part 170. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Harper Oil Company 2319 W. Jefferson Springfield, IL 62702</p> <p>Contact: Patrick Ketchum (217) 698-4088</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Harper Oil Co #18 1028 N. 9th Street Springfield, Sangamon Co., IL</p> <p>Contact: Patrick Ketchum (217) 698-4088</p>
---	---

(3) INSPECTION OF INTERIOR LINING OF TANKS:

- (a) *Number and size of tanks being inspected:* (TK # 4) - 8,000 gallons, (TK # 5) - 4,000 gallons
- (b) *Type of tanks:* (TK # 4, 5) - Existing single wall steel
- (c) *Product stored in each tank:* (TK # 4) - Diesel Fuel, (TK # 5) - Kerosene
- (d) *Manway accessible at grade:*

- (4) **Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.**
- (5) **The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**
- (6) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). According to our records these tanks were originally lined 08/20/86. Later, an inspector log for permit #5641 REL states three tanks were lined in August 1990 - one 2000 gallon K-1, one 4000 gallon diesel, and one 10000 gallon gasoline; consequently, it is possible and probable that tank #5 was lined again through that permit, but because of tank size and product inconsistency in the file records, it cannot be determined positively. Furthermore, a certification audit received 10/30/00 claims tanks 4 & 5 had a lining inspection performed in July of 1995; however, we have absolutely no records (permits, logs, field notes, etc.) to prove this. A lining inspection permit was applied for to inspect tanks 4 & 5 on Dec. 27, 2000; however, the permit was cancelled by the contractor. Then, an NOV progress report, and certification audits from an inspector states the tanks were inspected 01/22/01. If this is the case, then it was done without a permit, and we also do not have field notes, inspector permit log, or contractor signed notification form to verify the inspection. Whatever the case may be these tanks are past due for inspection.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Superior Equipment Co Inc 3283 Ivanhoe Ave</p>	<p>Contact Person: James H Spiros Phone: Contractor Registration # Exp.</p>

Sincerely,

James J Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)