



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 1-009417
Permit # 00950-2012UPG
Request Rec'd 09/06/2012
Amended Date
Approval Date 9/6/2012 JC
Permit Expires 3/6/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: AHR, Inc. 110 North Main Street Sandwich, IL 60548 Contact: Roshid Blutta (815) 786-8504	(2) FACILITY - name and address where tanks are located: Larson 66 (Citgo) 120 North Main Street Sandwich, De Kalb Co., IL Contact: Roshid Blutta (815) 786-8504
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 6) - 10,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 6) - (Installing) Dispenser Sump containment FRP under the existing dispenser that is located just south of, and next to, the existing northern most dispenser, (TK # 6) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX from the existing line (formerly extending to the now discontinued northern most dispenser) to the dispenser located next to, and just south of it. The northern most dispenser will be discontinued; however, no underground piping will be removed. The existing piping will hook into the new section of partial piping that will extend to the existing dispenser just south of it. **(see site plan).**

(d) *Product to be stored in each tank:* (TK # 6) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 6) - (Installing) Piping Sump Sensor Interstitial Monitoring Veeder Root TLS 350 under the existing dispenser located just south of the existing (to be discontinued) northern most dispenser.

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 6) - (Installing) partial Fiberglass Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Mokena, IL 60448	Contact Person: Chris Derro Phone: (708) 478-6190 Ext. 231 Contractor Registration # IL-002275 Exp.
---	---

Sincerely,

