

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 1-031212
Permit # 00946-2012UPG
Request Rec'd 09/05/2012
Amended Date
Approval Date 9/6/2012 DS
Permit Expires 3/6/2013

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104	Sandy Hollow Mobil 1621 Sandy Hollow Road Rockford, Winnebago Co., IL
Contact: John Griffin (815) 397-9410	Contact: Amber Creviston (815) 379-7527

## (3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) 12,000 gallons, (TK # 2, 3) 8,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 1, 2, 3) (Installing) Dispenser Sumps containment FRP, (TK # 1, 2, 3) (Installing) Fiberglass Double Wall Ameron Dualoy 3000/L Vent Piping, (TK # 1, 2, 3) (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX Product Piping from tanks to new dispenser islands, (TK # 1, 2, 3) (Installing) Submersible Sumps containment FRP
- (d) Product to be stored in each tank: (TK # 1, 2, 3) Gasoline
- (e) Type of leak detection being used:

Tank:

**Piping:** (TK # 1, 2, 3) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350, (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all submersible and dispenser sumps

(f) Corrosion Protection being used:

Tank:

**Piping:** (TK # 1, 2, 3) - (Installing) Fiberglass Non-Corrosive

- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3) (Installing) Manhole Pre-manufactured OPW 1C-2100C-DEVR
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Nate Meyer Phone: (815) 398-6250

Caniel y. Starke

Rockford, IL 61104 Contractor Registration # Exp.

Sincerely,

Daniel Starks

(Rev. - 9/10)