



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-003024
Permit # 00626-2006LIN
Request Rec'd 05/02/2006
Amended Date
Approval Date 5/3/2006 JC
Permit Expires 11/3/2006

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Part 170. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Lee Mobil Inc 9118 S Kedzie Ave Evergreen Park, IL 60805 Contact: Langand Mark (708) 425-9250	(2) FACILITY - name and address where tanks are located: Lee's Citgo Inc 9118 S Kedzie Ave Evergreen Park, Cook Co., IL Contact: Tom Langland (708) 425-9250
---	---

(3) INSPECTION OF INTERIOR LINING OF TANKS:

- (a) Number and size of tanks being inspected:* (TK # 1, 2) - 7,500 gallons
- (b) Type of tanks:* (TK # 1, 2) - Existing single wall steel
- (c) Product stored in each tank:* (TK # 1, 2) - Gasoline
- (d) Manway accessible at grade:*

(4) Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.

(5) The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(6) SPECIAL CONTINGENCIES: Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Tanks were originally lined through permit #2346 REL sometime in December of 1990 according to a notification form and permit application. Tanks were then inspected through permit #01689-2000LIN on 11/22/00. A Timely Compliance Opportunity letter was issued for this site on 03/22/06 allowing this facility 60 days to come into compliance. If compliance is not achieved by 05/21/06 the non-compliant underground storage tank(s) will be red-tagged.

<u>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Bolin Enterprises, Inc. P.O. Box 70,	Contact Person: James Bolin Phone: Contractor Registration # Exp.
---	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)