



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-008131
Permit # 00489-2006REM
Request Rec'd 04/04/2006
Amended Date
Approval Date 4/6/2006 JC
Permit Expires 10/6/2006

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Wood Dale Union 76, Inc. 217 E. Irving Park Rd. Wood Dale, IL 60191 Contact: Ali Eyad (630) 595-4233	(2) FACILITY - name and address where tanks are located: Wood Dale Union 76, Inc. 217 E. Irving Park Wood Dale, Du Page Co., IL Contact: Ali Eyad (630) 595-4233
--	---

(3) REMOVAL OF TANKS:

(a) *Number and size of tanks being removed:* (TK # 1, 2, 3) - 8,300 gallons

(b) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline

(c) *Reason of tanks being removed:*

(d) *If tank(s) is leaking, indicate IEMA incident number:* 060382

(e) *Date each tank was last used:* (TK # 1), (TK # 2), (TK # 3)

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: The application for this permit arrived showing 6 more tanks that are "possibly" on site. At this point it cannot be confirmed if they are pre or post 74 tanks, or if they are even there at all. If it is determined before or during removal of tanks 1,2,3 that the 6 "unregistered" tanks are pre-74, the permit can be field amended to include those tanks for removal under this permit (the contractor must immediately notify Jim Coffey at 217-524-0769 and fax in a statement declaring the fact that the permit is being field amended, and that the tanks are pre-74). If the tanks are not pre-74, they will not be allowed to be removed under this current permit. Late registration fees totalling \$3500.00 will have to be paid, a notification form to register the tanks will have to be sent in, and a new removal permit will be required for the removal of those tanks. These issues were discussed with Doug Harmon 04/06/06 at 10:00a.m. This issue is especially important in the fact that this site has an IEMA incident number (the contamination will have to be cleaned up, which also means that the late registration fees would have to be paid by either the former owner or current owner before the L.U.S.T. fund can be accessed). Furthermore, an installation permit also arrived for this site to install tank #'s 4,5,6,7 ; consequently, if those 6 other "possible" tanks are found, they will be identified as I.D. #'s 8,9,10,11,12,13.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

600 E. Joe Orr Road

Contact Person:

Phone:

Contractor Registration # Exp.

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)