

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 4-007070 Permit # 00078-2006UPG Request Rec'd 11/16/2005 Amended Date Approval Date 1/11/2006 JC Permit Expires 7/11/2006

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Speedway SuperAmerica, LLC P.O. Box 1500 Springfield, OH 45501-1500	Speedway Unit 5205 3798 N Woodford St Decatur, Macon Co., IL
Contact: Danny Coffey (937) 863-7072	Contact: John M Helms (937) 864-3000

## (3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) 15,000 gallons, (TK # 5, 7) 10,000 gallons, (TK # 6, 8) 4,000 gallons
- (b) Type of tanks: (TK # 4, 5, 6, 7, 8) Existing single wall fiberglass
- (c) Type of piping: (TK # 4, 5, 6, 7, 8) Existing double wall fiberglass, (TK # 4, 5, 6, 7, 8) Existing Existing steel flex connectors
- (d) Product to be stored in each tank: (TK # 4, 5, 7) Gasoline, (TK # 6) Kerosene, (TK # 8) Diesel Fuel
- (e) Type of leak detection being used:

Tank: (TK # 4, 5, 6, 7, 8) - (Installing) Veeder Root TLS 350 with CSLD automatic tank gauge

*Piping:* (TK # 4, 5, 7, 8) - (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 4, 5, 7, 8) - Existing interstitial monitoring, (TK # 6) - Existing European Suction

(f) Corrosion Protection being used:

Tank:

*Piping:* (TK # 4, 5, 6, 7, 8) - Existing fiberglass, (TK # 4, 5, 6, 7, 8) Existing Flex connector sacrificial spike anode cathodic protection

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
	Contractor Registration #	Exp.

Jame J Coffey

Sincerely,

Jim Coffey