



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 6-007996
Permit # 00072-2006REM
Request Rec'd 11/29/2005
Amended Date
Approval Date 1/11/2006 JC
Permit Expires 7/11/2006

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: L. Keller Oil Properties, Inc. # 4 Avenue of Mid-America, P.O. Box 70 Effingham, IL 62401 Contact: Mr. Keller (217) 347-7777	(2) FACILITY - name and address where tanks are located: Jack Flash - Farina I-57 & Rt. 185 Farina, Fayette Co., IL Contact: Joe Henry (217) 347-7777
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 1, 2, 3) - 8,000 gallons
- (b) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (c) *Reason of tanks being removed:* Discontinue usage
- (d) *If tank(s) is leaking, indicate IEMA incident number:* 05-1539
- (e) *Date each tank was last used:* (TK # 1, 2, 3) - 11/15/2005

- (4) **The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

- (5) **SPECIAL CONTINGENCIES:** STSS must field verify the existence and compliance of tank #5 (1000 gallon heating oil). This tank was acknowledged by a certification audit from STSS Wayne Sensel on 01/14/00. He stated the tank was exempt until 06/01/2000. Later certification audits have not addressed this tanks existence. According to our records, we show only that the tank is a steel tank (there is no other info on this tank - it was registered 06/30/1992). Furthermore, tank #4 (12000 gallon diesel) appears to have impressed current system for tank and piping via permit #05578-1998UPG; however, we do not have a log, nor a notification form to verify if it was installed or not (recent certification audits indicate this particular tank is using manual tank gauging / inventory control). A Timely Compliance Opportunity letter was issued for this site (tanks 1,2,3,4) on 01/12/05 allowing this facility 60 days to come into compliance. If compliance is not achieved by 03/13/05 the non-compliant underground storage tank(s) will be red-tagged.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: 701 West South Grand Avenue	Contact Person: Phone: Contractor Registration # Exp.
--	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)