



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 4-010275
Permit # 00273-2006FLX
Request Rec'd 02/22/2006
Amended Date
Approval Date 2/22/2006 JC
Permit Expires 8/22/2006

Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Capital Business Management LLC P.O. Box 1231 Mattoon, IL 61938 Contact: Leonard Demian (612) 978-4389	(2) FACILITY - name and address where tanks are located: Friendly Food Mart 1321 Lakeland Blvd. Mattoon, Coles Co., IL Contact: Leonard Damien (678) 978-4389
--	--

(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons, (TK # 3) - 4,000 gallons
- (b) Type of flex connector(s):* (TK # 1, 2, 3) - Existing steel flex connectors
- (c) Product stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (d) Corrosion Protection being installed with flex connector(s):* (TK # 1, 2, 3) - (Installing) Flex connector sacrificial spike anode cathodic protection

- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

- (5) SPECIAL CONTINGENCIES:** Permit #00272-2006UPG is valid until 08/22/06 to install an automatic tank gauge. STSS must field verify what type of piping this facility has. Information in file goes back and forth from fiberglass to steel and back and forth again and again. According to permit #05360-1998UPG, the tanks AND piping both had impressed current installed (the log for the permit "verifies" it was installed). Field notes have been found concerning the lining condition for all three tanks stating no leaks or holes were found (Armor Shield notes from 01/10/03). Tank #3 was lined 05/11/87, and tank #1 & #2 was lined 02/09/99. Permit #00251-2006LIN was issued 02/15/06 for tank #3. These three tanks were red tagged on 01/30/06.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Midwest Petroleum Service Danville, IL 61834	Contact Person: Phone: Contractor Registration # Exp.
---	--

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)