



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 1-042306
Permit # 00256-2006FLX
Request Rec'd 12/01/2005
Amended Date
Approval Date 2/16/2006 JC
Permit Expires 8/16/2006

**Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stop &amp; Country Stores        P.O. Box 26210        Oklahoma City, OK 73126</p> <p>Contact: Michael Key</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Love's Travel Stop #322        13477 Quality Drive        Roscoe, Winnebago Co., IL</p> <p>Contact:</p>
--	---

**(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3) - 20,000 gallons
- (b) *Type of flex connector(s):* (TK # 1, 2, 3) - (Installing) Steel flex connectors
- (c) *Product stored in each tank:* (TK # 1, 2, 3) - Diesel Fuel
- (d) *Corrosion Protection being installed with flex connector(s):* (TK # 1, 2, 3) - Existing containment sump

**(4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:** This work has been previously completed under emergency repair procedures. Contractor is installing new flex connector under dispenser #20 (original emergency request paperwork said dispenser #17; however, a call to Greg Burkheimer on 02/16/06 stated it is for dispenser #20) to replace an existing leaking flex connector. According to emergency request from contractor, this work was performed the week of 11/07/05.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Oil Equipment Company, Inc.</p> <p>Madison, WI 53704</p>	<p>Contact Person:</p> <p>Phone:</p> <p>Contractor Registration #    Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)