



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-010716
Permit # 00114-2006REM
Request Rec'd 01/09/2006
Amended Date
Approval Date 1/17/2006 JC
Permit Expires 7/17/2006

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Kooshtard Property VIII, LLC 1370 Avenue of America's 29th Floor New York, NY 10019 Contact: Matt McCure (812) 379-9227	(2) FACILITY - name and address where tanks are located: Coal City Shell #1813 10 W. Division Street Coal City, Grundy Co., IL Contact: Kevin Merrett
---	--

(3) REMOVAL OF TANKS:

- (a) **Number and size of tanks being removed:** (TK # 3) - 4,000 gallons, (TK # 4) - 2,000 gallons
- (b) **Product stored in each tank:** (TK # 3, 4) - Gasoline
- (c) **Reason of tanks being removed:** Removing the siphon bar only from tank ID #3 & #4.
- (d) **If tank(s) is leaking, indicate IEMA incident number:**
- (e) **Date each tank was last used:** (TK # 3), (TK # 4) - 09/09/2004

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

- (5) SPECIAL CONTINGENCIES:** This permit is to remove an existing siphon bar between tanks 3 & 4 only. Tank #1 is past due for lining inspection (Tanks 1,2,3,4 were originally lined 08/25/89). Tanks 1,2,3,4 were then inspected 01/04/01 from permit #01609-2000LIN. At that time it was determined tanks 2,3,4 had to be relined (they were relined 04/06/01 permit #00381-2001REL). Tank #1 at that time passed the inspection; consequently tank #1 is now due for the five year re-inspection.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: 2421 Washington Road	Contact Person: Phone: Contractor Registration # Exp.
---	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)