



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 5-029326
Permit # 00033-2006FLX
Request Rec'd 01/03/2006
Amended Date
Approval Date 1/5/2006 MB
Permit Expires 7/5/2006

Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sangamon County Building & Grounds 200 S. 9th Street, Room 205 Springfield, IL 62701 Contact: Paul Davis (217) 535-3129	(2) FACILITY - name and address where tanks are located: Sangamon Co. Court & Detention Complex 200 S. 9th Street, Room 205 Springfield, Sangamon Co., IL Contact: Rick Baker (217) 535-3129
---	---

(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:

- (a) Number and size of tanks being upgraded or repaired:** (TK # 1) - 971 gallons
- (b) Type of flex connector(s):** (TK # 1) - Existing steel flex connectors
- (c) Product stored in each tank:** (TK # 1) - Diesel Fuel
- (d) Corrosion Protection being installed with flex connector(s):** (TK # 1) - (Installing) Sacrificial anodes cathodic protection

- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**
- (5) SPECIAL CONTINGENCIES:** A Timely Compliance Opportunity letter was issued for this site on 12/05/2005 allowing this facility 60 days to come into compliance. If compliance is not achieved by 02/03/2006 the non-compliant underground storage tank(s) will be red-tagged.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: W J Scott Co <hr/> Springfield, IL 62707	Contact Person: _____ Phone: _____ Contractor Registration # _____ Exp. _____
--	---

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)