



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY

Facility # 2-001563
Permit # 00411-2013UPG
Request Rec'd 05/10/2013
Amended Date 06/11/2013
Approval Date 5/10/2013 JC
Permit Expires 11/10/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: St. Charles School District # 303 201 South 7th Street St. Charles, IL 60174 Contact: Blanca Souders (630) 377-4819	(2) FACILITY - name and address where tanks are located: Thompson Middle School 705 West Main Street St. Charles, Kane Co., IL Contact: Ken Farley (630) 377-4885
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) Flexible Double Wall OPW Flexworks non corrosive from the tank sumps **(2)** to the new European suction pumps at the two existing dispenser locations (this replaces the existing piping runs). **There will be a new tank sump installed per amended site plan. See contingencies section for further detail.**
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline
- (e) *Type of leak detection being used:*
 - Tank:**
 - Piping:** (TK # 1) - (Installing) European with No Test Req Suction , (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 300c **at the two dispenser sumps only.**
- (f) *Corrosion Protection being used:*
 - Tank:**
 - Piping:** (TK # 1) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Amendment request was received 06/11/13 to include the installation of a second tank sump to allow for independent product draw from independent lines for each of the two dispensers. Also, there will only be two sump sensors installed instead of three (one sensor installed at each dispenser sump only - there will not be any sensors installed at the tank sumps).

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Superior Petroleum Marketers, Inc.
2336 Albright Lane , P. O.Box 4648
Wheaton, IL 60189-4648

Contact Person: Steve Tuttle
Phone: (630) 588-1198

Contractor Registration # IL-2087 Exp. 02/04/2014

Sincerely,

Jim Coffey

