



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

| |
|----------------------------|
| <u>FOR OFFICE USE ONLY</u> |
| Facility # 4-033704 |
| Permit # 00590-2013UPG |
| Request Rec'd 06/19/2013 |
| Amended Date |
| Approval Date 6/19/2013 DS |
| Permit Expires 12/19/2013 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|--|--|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: JDN Corporation 8 S. 167 Hampton Circle Naperville, IL 60540 Contact: Narahin Gulabani (630) 235-7828</p> | <p>(2) FACILITY - name and address where tanks are located: Marathon 3401 East Main Danville, Vermilion Co., IL Contact: Santosh Poudyal (217) 446-8239</p> |
|--|--|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC
- (d) *Product to be stored in each tank:* (TK # 3) - Diesel Fuel
- (e) *Type of leak detection being used:*
 Tank:
 Piping: (TK # 3) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) *Corrosion Protection being used:*
 Tank:
 Piping: (TK # 3) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) **The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) **SPECIAL CONTINGENCIES:** Contractor indicates that the existing manifold line for tanks #2&3 will be capped off, and tank #3 will become B-11 to supply dispenser. Contractor also states that there are existing sumps and sensors at tank and dispenser.

| | |
|---|---|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Seneca Companies, Inc. 458 N. Highway 48 Oreana, IL 62554 | Contact Person: Chuck Hoenig Phone: (217) 468-2393 Contractor Registration # IL-598 Exp. 02/23/2014 |

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
 Fire Department -
 Division File
 (Rev. - 9/10)