



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**FOR OFFICE USE ONLY**  
Facility # 6-016407  
Permit # 00595-2013UPG  
Request Rec'd 06/20/2013  
Amended Date  
Approval Date 6/20/2013 JC  
**Permit Expires 7/5/2013**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Clinton County Oil Company, Inc. P.O. Box 155 Breese, IL 62230 Contact: Gene Bickl (618) 526-7570	<b>(2) FACILITY</b> - name and address where tanks are located: C C Food Mart 1221 12th Street Carlyle, Clinton Co., IL Contact: Sarah Nelson (618) 594-8404
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 6) - 15,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 6) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX to repair a very short piece of product piping inside the existing submersible sump due to a pin hole leak.
- (d) Product to be stored in each tank:* (TK # 6) - Gasoline
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) SPECIAL CONTINGENCIES:** All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). Emergency repair request was received 06/19/13. The final inspection must be scheduled by 07/05/13.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> United Petroleum Service, Inc. 1458 Collins Street Saint Louis, MO 63102	Contact Person: Harvey Stokes Phone: (314) 241-3767 Contractor Registration # IL-246 Exp. 05/28/2014
---	--

Sincerely,

Jim Coffey

