



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-016014
Permit # 00596-2013UPG
Request Rec'd 06/20/2013
Amended Date
Approval Date 6/20/2013 JC
Permit Expires 12/20/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sisters of St. Francis 1423 Chicago Rd. Chicago Heights, IL 60411 Contact: Urban Rick (708) 756-1000	(2) FACILITY - name and address where tanks are located: St. James Hosp & Health Center 1423 Chicago Rd. Chicago Heights, Cook Co., IL Contact: Rick Urban (708) 756-1000
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 2) - (Installing) ATG probe riser to replace the existing riser (see contingencies section for further details).
- (d) *Product to be stored in each tank:* (TK # 2) - Diesel Fuel
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Contractor is replacing the ATG probe riser due to a hole that has formed that is allowing water intrusion to the tank. Also, this permit may be amended to include replacement of the existing vent line, if upon further investigation the contractor finds it necessary. The amendment request will require a site sketch indicating the route of the new vent line. Vent lines must be tested at 7 psi minimum or at a pressure recommended by the manufacturer. All steel risers, vents, and fills in contact with the ground, backfill or water shall be dielectrically wrapped or coated.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Interstate Pump & Tank, Inc.
901 Niagara Street
Waukesha, WI 53186

Contact Person: Dan McMahon
Phone: (262) 524-8494

Contractor Registration # IL-1171 Exp. 05/07/2014

Sincerely,

Jim Coffey

