



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY

Facility # 1-043275
Permit # 00368-2013UPG
Request Rec'd 05/02/2013
Amended Date 06/25/2013
Approval Date 5/20/2013 JC
Permit Expires 11/20/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Manlius Oil Co., Inc. 8792 2175 N. Avenue, Sheffield, IL 61361 Contact: Mitchell Doty (815) 445-3122	(2) FACILITY - name and address where tanks are located: Manlius Oil Co., Inc. 8972-2175 N. Ave. Sheffield, Bureau Co., IL Contact: Mitchell Doty (815) 445-3122
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 2) - (Installing) Dispenser Sumps containment FRP to accommodate the installation of the new semi-truck fueling dispensers (1 master dispenser and 2 satellite dispensers), (TK # 2) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from the tank to the new semi-truck fueling dispensers per site plan (1 master dispensers and 2 satellite dispensers).

(d) Product to be stored in each tank: (TK # 2) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 300c at the new semi-truck fueling dispenser sumps only. There is an existing sensor at the submersible sump and an existing line leak detector.

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 2) - (Installing) Fiberglass Non-Corrosive

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: Amendment request was received 06/25/13 (the amendment is to correct the site plan to show this is a three compartment tank and not individual tanks as was permitted; therefore, the piping from tank #2 will be configured slightly different than what was shown on the original site plan for this permit). MLLD is existing. The underground storage tank system for tank #3 must be compatible with E-85, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76., no. 128, July 5th 2011 Notices regarding the storage and dispensing of alternative / blended fuels.

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> IL Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp. 02/04/2014
---	--

Sincerely,

A handwritten signature in dark ink, reading "James J. Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)