



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-045403
Permit # 00623-2013ABN
Request Rec'd 06/28/2013
Amended Date
Approval Date 7/1/2013 JC
Permit Expires 1/1/2014

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sherman Gardens Apartment Trust 1856-1866 Sherman Evanston, IL 60201 Contact: Gregg Rithmiller (847) 866-7400	(2) FACILITY - name and address where tanks are located: Sherman Garden Apartments 1856-1866 Sherman Evanston, Cook Co., IL Contact: Gregg Rithmiller (847) 866-7400
---	---

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned:* (TK # 1, 2) - 10,000 gallons
- (b) Product stored in each tank:* (TK # 1, 2) - Fuel Oil
- (c) Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: H20130691
- (d) Location of piping being abandoned:* Any associated piping must either be removed (if physically possible) or abandoned.

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES:** Tanks will be filled with flowable fill concrete slurry mix. The tanks are situated between the foundations of two structures, one off-site, and one on-site. Excavation of the tanks would compromise these foundations. There is also a small shed structure above one tank and a large tree immediately adjacent. Site assessment is on file.

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

<u>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Tsarpalas Enterprises, Inc. 17494 West Hickory Lane Grayslake, IL 60030	Contact Person: Steve A Tsarpalas Phone: (847) 816-8828 Contractor Registration # IL-297 Exp. 05/10/2014
---	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)