



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-007847
Permit # 00621-2013UPG
Request Rec'd 06/28/2013
Amended Date
Approval Date 7/3/2013 JC
Permit Expires 1/3/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: AT&T Corp. d/b/a Illinois Bell 308 S. Akard, Room 1700 Dallas, TX 75202 Contact: Lisa Espinosa (800) 566-9347	(2) FACILITY - name and address where tanks are located: Elmhurst 152 South York Road Elmhurst, Du Page Co., IL Contact: Agron (331) 442-1388
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 2) - 2,500 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 2) - (Installing) partial Fiberglass Single Wall vent Piping to repair / replace the existing vent line due to problems with the tank taking on water. The contractor will excavate outside the concrete tank pad, and will cut and test the portion back to the UST piping sump. If the test holds, the existing bad portion of the vent piping located under the remote radiator for the generator will be abandoned (an abandonment permit will NOT be necessary to do this since it is vent piping). Once this occurs, the contractor will terminate the vent at the chain link fence that surrounds the remote radiator for the generator. If the vent line is damaged under the UST concrete pad, the contractor will install a new vent line from the UST piping sump to the chain link fence that surrounds the remote radiator from the generator (see site plan and job summary).
- (d) Product to be stored in each tank:* (TK # 2) - Diesel Fuel
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) SPECIAL CONTINGENCIES:** Vent lines must be tested at 7 psi minimum or at a pressure recommended by the manufacturer. All steel risers, vents, and fills in contact with the ground, backfill or water shall be dielectrically wrapped or coated.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

J & D Mechanical Industries, Inc.
6521 Main Street, Suite A, P.O. Box 113
Union, IL 60180

Contact Person: Cheryl Zielke
Phone: (815) 923-4510

Contractor Registration # IL-1943 Exp. 04/26/2014

Sincerely,



Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)