



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**FOR OFFICE USE ONLY**

Facility # 2-021942  
Permit # 00643-2013UPG  
Request Rec'd 07/03/2013  
Amended Date  
Approval Date 7/10/2013 JC  
Permit Expires 1/10/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Thorn Creek Sanitary District 700 W. End Avenue Chicago Heights, IL 60411 Contact: Jeff Quigley (708) 754-0525	<b>(2) FACILITY</b> - name and address where tanks are located: Monee Road Lift Station SW Corner Monee Rd Western Park Forest, Cook Co., IL Contact: Johnson Allan E (312) 754-0525
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 4,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 2) - (Installing) Flexible Double Wall OPW Flexworks CP-15 non corrosive supply and return lines to replace the existing underground piping - from the tank to the pump house building foundation, where it will transition from underground piping to the existing above grade steel piping within the pumphouse. Contractor states there is an existing piping sump at the tank.
- (d) *Product to be stored in each tank:* (TK # 2) - Diesel Fuel
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:* (TK # 2) - (Installing) European with No Test Req Suction
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:* (TK # 2) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES: Refer also to section 175.640(b)(2)(E).**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: (708) 474-3344 Contractor Registration # IL-1207 Exp. 02/14/2014
--	---

Sincerely,

Jim Coffey

