



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**FOR OFFICE USE ONLY**

Facility # 3-015803  
Permit # 00667-2013UPG  
Request Rec'd 07/11/2013  
Amended Date  
Approval Date 7/11/2013 JC  
**Permit Expires 7/25/2013**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Bethany Enterprises 101 Woodland Road, Milan, IL 61264 Contact: William Ernst (309) 787-2827	<b>(2) FACILITY</b> - name and address where tanks are located: QC Mart 101 Woodland Park Rd Milan, Rock Island Co., IL Contact: Cindy Bisby (309) 738-1419
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 6,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 1) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P150SC from the existing submersible sump to the first existing dispenser sump only (this is to replace the existing damaged "section / run" of piping). Contractor states there is an existing sump at the submersible and at the first dispenser.

(d) *Product to be stored in each tank:* (TK # 1) - Gasoline

(e) *Type of leak detection being used:*

*Tank:*

*Piping:* (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the submersible sump and at the first dispenser sump only.

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:* (TK # 1) - (Installing) partial Flexible Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). Emergency repair request was received by Dan on 07/09/13. The final inspection must be scheduled by 07/25/13. Refer also to 175.420(b) for sensor requirement.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Central Petroleum Equipment Company 109 Terrace Drive Blue Grass, IA 52726	Contact Person: Roger L Clark Phone: (563) 381-5092 Contractor Registration # IL-345 Exp. 06/12/2014
---	--

Sincerely,



---

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)