



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 7-042092
Permit # 00652-2012INS
Request Rec'd 07/05/2012
Amended Date 08/20/2012
Approval Date 7/11/2012 JC
Permit Expires 1/11/2013

Amended

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 Oklahoma City, OK 73126 Contact: Michael Key (405) 302-6640	(2) FACILITY - name and address where tanks are located: Love's Travel Stop #318 202 North Avenue Ina, Jefferson Co., IL Contact: General Manager (405) 302-6640
---	---

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 7) - 20,000 gallons, (TK # 8) - 12,000 gallons
- (b) **Type of tanks:** (TK # 7, 8) - (Installing) Fiberglass Double Wall XERXES
- (c) **Type of piping:** (TK # 7, 8) - (Installing) Fiberglass Double Wall Ameron product piping and remote fill piping (**see contingencies section and the site plan**).
- (d) **Product to be stored in each tank:** (TK # 7) - Diesel Fuel, **(TK # 8) - Diesel Exhaust Fluid (Non-Regulated)**
- (e) **Type of leak detection being used:**
 - Tank:** (TK # 7, 8) - (Installing) Interstitial Monitoring Veeder Root TLS 350, (TK # 7, 8) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 probes only (the existing console will be used for these tanks).
 - Piping:** (TK # 7, 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the remote fill ends / submersibles that are located at the tanks, and also installing a sensor at the new metering sump (there are existing sensors at the submersible sumps for tanks #1 and #3, an existing sensor at the tank sump for tank #2, and existing sensors at the two existing metering sumps), (TK # 7, 8) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) **Corrosion Protection being used:**
 - Tank:** (TK # 7, 8) - (Installing) Fiberglass Non-Corrosive
 - Piping:** (TK # 7, 8) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping and dispenser containment devices:** (TK # 7, 8) - (Installing) Field Constructed basin (essentially integrating with the existing spill containment basin for tanks 1,2,3).
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Chris Epkins Phone: Contractor Registration # IL-1293 Exp.

Sincerely,

