



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY

Facility # 3-025522
Permit # 00542-2013UPG
Request Rec'd 06/11/2013
Amended Date 07/29/2013
Approval Date 6/12/2013 JC
Permit Expires 12/12/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Detweiller Playground, Inc. 301 SW Adams Street, 1st of America Bank Peoria, IL 61631 Contact: Angie Lawless (309) 683-3770	(2) FACILITY - name and address where tanks are located: Detweiller Marina Foot of Caroline Street Peoria, Peoria Co., IL Contact: Denny Gardner (309) 370-6767
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 6,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 3) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech MarinaFlex metallic ducted to repair a damaged section from the shoreline transtion sump to the transtion sump located at the dock nearest the shoreline only.

(d) *Product to be stored in each tank:* (TK # 3) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Owens Corning TGMS-08 Piping Sump Sensor in the existing transtion sump located at the beginning of the dock near the river bank. Contractor states there is an existing sensor at the existing transition sumplactaed at the rocky slope shoreline.

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Amendment request was received 07/25/13 to replace the section of piping from the existing transtion sump located at the edge of the sidewalk near the rocky slope to the existing transition sump located at the edge of the river bank on the dock.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: IL Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp. 02/04/2014
--	--

Sincerely,



Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)