



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

## Amended

FOR OFFICE USE ONLY

Facility # 2-034732

Permit # 00585-2013UPG

Request Rec'd 06/18/2013

**Amended Date 07/30/2013**

Approval Date 6/19/2013 JC

Permit Expires 12/19/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: RDK Ventures, LLC 4080 W. Jonathan Moore Pike Columbus, IN 47201 Contact: Noel Newsom (800) 844-8661 Ext. 1436	<b>(2) FACILITY</b> - name and address where tanks are located: Circle K #6725 280 North Illinois Route 31 Crystal Lake, McHenry Co., IL Contact: Steve Boleyn (815) 459-4558
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 15,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 1, 2) - **(Installing) partial Flexible Double Wall Containment Technologies Corporation Perma Flexx (see the contingencies section and site plan for complete details).**

(d) *Product to be stored in each tank:* (TK # 1, 2) - Gasoline

(e) *Type of leak detection being used:*

*Tank:*

*Piping:* (TK # 1, 2) - **(Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the first dispenser sump and at the second dispenser sump only (see contingencies section).**

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:* (TK # 1, 2) - **(Installing) partial Flexible Non-Corrosive within existing fiberglass secondary chase duct.**

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Amendment request to alter the amount of piping to be removed and installed was received 07/30/13 - see amended site plan for details of the minor re-routing of piping between the two existing dispensers on the building side of Illinois route 31 only. See amended permit #00584-2013REM for the removal of partial existing product piping, and removal of two existing dispensers located on the Illinois route 31 side of the building (the other four existing dispensers at this site will remain). The majority of the existing chase duct and majority of product piping will remain. See amended site plan for the removal permit, and for this permit. Under the amended conditions of this permit, there will only be a requirement for interstitial sensors to be installed at the first and second existing dispensers because piping will only be "replaced / re-routed" for that particular "run" of piping between those two existing dispensers as opposed to the "original" plans of this permit.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Hoyt Ary Phone: (708) 478-6190 Ext. 231 Contractor Registration # IL-002275 Exp. 05/21/2014
---	---

Sincerely,

A handwritten signature in cursive script, reading "James J. Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)