



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-015829
Permit # 00737-2013UPG
Request Rec'd 08/01/2013
Amended Date
Approval Date 8/1/2013 JC
Permit Expires 8/15/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: MLRP Bridgeview Complex, LLC One Pierce Place, Suite 450 Itasca, IL 60143 Contact: Brian Cosler (708) 594-2200	(2) FACILITY - name and address where tanks are located: Carry Transit 7830 West 71st Street Bridgeview, Cook Co., IL Contact: Katie Kinkade (708) 594-2200 Ext.
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 15,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3) - (Installing) Flex Connector Steel to replace the existing leaking flex connector at the existing submersible sump only.
- (d) *Product to be stored in each tank:* (TK # 3) - Diesel Fuel
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Emergency repair request was received 07/29/13. All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 08/15/13. There is an outstanding NOV for this tank system #E0020131941.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Ampsco Service Corporation 4635 South Harlem Forest View, IL 60402	Contact Person: Stephen Kryl Phone: (708) 795-9052 Contractor Registration # IL-002332 Exp. 10/15/2014
---	--

Sincerely,

Jim Coffey

