



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 5-024861
Permit # 00778-2013REM
Request Rec'd 08/08/2013
Amended Date
Approval Date 8/8/2013 JC
Permit Expires 2/8/2014

Partial piping removal only

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Chronister Oil Company 2026 Republic, Springfield, IL 62702 Contact: Grady Chronister (217) 523-5050	(2) FACILITY - name and address where tanks are located: Qik-N-EZ 1995 W. Monroe Springfield, Sangamon Co., IL Contact: Cathleen Bergai
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tank:* (TK # 4) - 4,000 gallons
 - (b) *Description/location of piping being removed:* ***See contingencies section and site plan.***
 - (c) *Product stored in each tank:* (TK # 4) - Diesel Fuel
 - (d) *Reason of being removed:* **Tank and majority of piping will remain existing (see contingencies section and site plan for further details).**
 - (e) *If tank(s) is leaking, indicate IEMA incident number:*
 - (f) *Date each tank was last used:* (TK # 4)
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** This permit is for the removal of partial piping / and existing dispenser #13 only (the tank and the majority of it's associated piping will remain). This piping removal section is between dispenser #13 and a new transition sump located between dispenser #9/10 and dispenser #1/2 (see site plan). Refer to amended permit #00605-2013UPG approved by Dan Starks for further details of this project. The underground storage tank system for tank #5 must be compatible with E-85, and tank system for tank #2 must be compatible with E-15 as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no.128, July 5th, 2011 notices regarding the storage and dispensing of alternative fuels.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
458 N. Highway 48
Oreana, IL 62554

Contact Person: Chuck Hoenig
Phone: (217) 468-2393

Contractor Registration # IL-598 Exp. 02/23/2014

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)