



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

**FOR OFFICE USE ONLY**  
 Facility # 4-033704  
 Permit # 00590-2013UPG  
 Request Rec'd 06/19/2013  
**Amended Date 08/15/2013**  
 Approval Date 6/19/2013 JC  
 Permit Expires 12/19/2013

**Amended**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          JDN Corporation          8 S. 167 Hampton Circle          Naperville, IL 60540          Contact: Narahin Gulabani (630) 235-7828</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Marathon          3401 East Main          Danville, Vermilion Co., IL          Contact: Santosh Poudyal (217) 446-8239</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC (contractor is unhooking and capping off the manifold portion of this piping, then running the new piping to dispenser #11).
- (d) *Product to be stored in each tank:* (TK # 3) - Diesel Fuel
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:* (TK # 3) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Amendment request was received 08/15/13 to reflect that a line leak detector will not be installed. Contractor indicates that the existing manifold line for tanks #2&3 will be capped off, and tank #3 will become B-11 to supply dispenser. Contractor also states that there are existing sumps and sensors at tank and dispenser.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Seneca Companies, Inc.          458 N. Highway 48          Oreana, IL 62554</p>	<p>Contact Person: Chuck Hoenig          Phone: (217) 468-2393          Contractor Registration # IL-598 Exp. 02/23/2014</p>

Sincerely,

Jim Coffey