



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 2-043308
 Permit # 00837-2013UPG
 Request Rec'd 08/20/2013
 Amended Date
 Approval Date 8/20/2013 JC
Permit Expires 9/4/2013

Emergency repair request

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Costco Wholesale Corporation 999 Lake Drive Isaquah, WA 98027</p> <p>Contact: Dennis Bock (425) 313-6048</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Costco Wholesale Retail Fueling Facility 9955 W. 159th Street Orland Park, Cook Co., IL</p> <p>Contact: Kim Sanford</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 30,000 gallons
 - (b) *Type of tanks:*
 - (c) *Type of piping:* (TK # 1) - (Installing) Flex Connector Steel to replace the existing leaking flex connector at dispenser sump # 9/10 only.
 - (d) *Product to be stored in each tank:* (TK # 1) - Gasoline
 - (e) *Type of leak detection being used:*
 Tank:
 Piping:
 - (f) *Corrosion Protection being used:*
 Tank:
 Piping:
 - (g) *Spill containment devices, piping, and dispenser containment devices:*
 - (h) *Overfill prevention devices:*
 - (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Emergency repair request was received 08/19/13. All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 09/04/13.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448</p>	<p>Contact Person: Chris Derro Phone: (708) 243-9081 Contractor Registration # IL-002275 Exp. 05/21/2014</p>

Sincerely,

Jim Coffey

