



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-045199
Permit # 00866-2012ABN
Request Rec'd 08/16/2012
Amended Date
Approval Date 8/20/2012 JC
Permit Expires 2/20/2013

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Galleria Venture LLC 4355 N. Ravenswood Ave. Chicago, IL 60613 Contact: John Rios (773) 327-8400	(2) FACILITY - name and address where tanks are located: 807 Church St. 807 Church St. Evanston, Cook Co., IL Contact: John Rios (773) 327-8400
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned:* (TK # 1) - 10,000 gallons
- (b) Location of tanks being abandoned:* **See contingencies section and site plan.**
- (c) Location of piping being abandoned:*

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES: Fill material will be low strength concrete slurry mix. UST is located in a basement under the floor. Site assessment is on file. Certificate of site condition indicates a clean site.**
- (6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> R. W. Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Alisa C Anderson Phone: (708) 458-6868 Contractor Registration # IL-772 Exp.
---	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)