



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-013285
Permit # 00852-2013UPG
Request Rec'd 08/26/2013
Amended Date
Approval Date 8/28/2013 DS
Permit Expires 2/28/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: PACE Suburban Bus 550 West Algonquin Road Arlington Heights, IL 60005 Contact: Dave Szaflarski (847) 228-4228	(2) FACILITY - name and address where tanks are located: Pace-North Div 1400 W 10Th St Waukegan, Lake Co., IL Contact: Dom Marzullo (847) 489-4069
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 20,000 gallons, (TK # 3) - 550 gallons, (TK # 5) - 1,000 gallons

(b) *Type of tanks:* (TK # 3, 5) - (Installing) Manway on tanks 3 & 5 and new FRP Collars on all three tanks

(c) *Type of piping:* (TK # 2, 3, 5) - (Installing) Submersible Sump (Tank #2) and tank top sumps on all tanks containment FRP, (TK # 3, 5) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from tanks to new transition sump, (TK # 3, 5) - (Installing) ONE Transition Sump FRP fiberglass inside building where piping will transfer above ground

(d) *Product to be stored in each tank:* (TK # 2) - Diesel Fuel, (TK # 3) - Automatic Transmission Fluid, (TK # 5) - Motor Oil

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 2) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350 to replace existing MLLD, (TK # 3, 5) - (Installing) American with Annual Prec Line Testing Suction to replace existing European Safe Suction, (TK # 3, 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in new submersible sump, all new tank sumps and in new transition sump

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 2, 3, 5) - (Installing) Fiberglass Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 2) - (Installing) Manhole Pre-manufactured OPW 1C-2115 DEVR spill containment manhole, (TK # 3, 5) - (Installing) Manhole Pre-manufactured OPW 101-2100

(h) *Overfill prevention devices:* (TK # 2, 3, 5) - (Installing) Overfill Drop Tube Valve OPW 61SO-4000

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Nate Meyer Phone: (815) 398-6250 Contractor Registration # IL-1890 Exp. 03/07/2014
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)