



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 7-011186
Permit # 00890-2013CAT
Request Rec'd 09/03/2013
Amended Date
Approval Date 9/4/2013 JC
Permit Expires 3/4/2014

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: A & S Enterprise of ILL PO Box 221 Carmi, IL 62821 Contact: Jason Smith (618) 382-7130	(2) FACILITY - name and address where tanks are located: Pundrake, A & S Enterprise of ILL 405 Fifth Street Carmi, White Co., IL Contact: Malinda Hobson (618) 382-7130
--	--

(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 1, 3, 4) - 10,000 gallons, (TK # 2) - 5,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank: (TK # 1, 2, 3, 4) - (Installing) Impressed Current Cathodic Protection anodes to replace the existing depleted anodes as per the original site diagram only.
Piping: (TK # 1, 2, 3, 4) - (Installing) Impressed Current Cathodic Protection anodes to replace the existing depleted anodes as per the original site diagram only.
- (g) *NACE certified designer:* *Certification number:*
- (h) *Method of integrity assessment of tank(s) being used:*

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Permit #01626-1999UPG installed impressed current for the steel tanks and steel piping for tanks 1,2,3,4. Permit #02235-2001INS installed a fiberglass tank and fiberglass piping.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Midwest Petroleum Service, LLC 23535 North 1530 East Road Danville, IL 61834	Contact Person: Mike Hall Phone: (217) 443-2263 Contractor Registration # IL-002306 Exp. 06/26/2014
--	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File

