



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 1-024482
Permit # 00891-2013REL
Request Rec'd 09/03/2013
Amended Date
Approval Date 9/5/2013 JC
Permit Expires 3/5/2014

Permit for INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to internally line underground storage tank(s) or piping is hereby granted. Such interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. Such interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sapp Bros., Inc. 9915 S. 148th Street Omaha, NE 68138 Contact:	(2) FACILITY - name and address where tanks are located: Sapp Bros. Travel Centers, Inc. 3130 May Road Peru, LaSalle Co., IL Contact: Kevin Cassidy (815) 224-1065
--	---

(3) INTERIOR LINING OF TANKS:

- (a) *Number and size of tanks being internally lined:* (TK # 1, 7, 8) - 12,000 gallons
 - (b) *Type of tanks:*
 - (c) *Name of manufacturer of internal lining material:* (TK # 1) Bridgeport Chemical
 - (d) *Designation of internal lining material:* (TK # 1) Glass Armor GA 27P
 - (e) *Product to be stored in each tank:* (TK # 1) - E-85, (TK # 7) - B-99, (TK # 8) - Diesel Fuel
(Internal lining material must be compatible with product stored in each tank)
 - (f) *Manway accessible at grade:* **Contractor states manways will be installed.**
- (4) This permit is VOID if tank is unacceptable for interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for interior lining and manway installation only. Separate permits are required to do interior tank lining inspections.
- (5) The owner must notify this Office when completion of tank internal lining has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (6) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. Contractor states this permit is for compatibility purposes of the existing fiberglass tanks for E-85 only. The underground storage tank system for tank #1,7,8 must be compatible with E-85 as indicated in section 175.415 (b) and (c) of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no.128, July 5th 2011 notices regarding the storage and dispensing of alternative fuels. With particular attention to all components of the UST and piping system under 175.400(a) and (c) / 175.420 (a) and (c) / 175.630 (d)(2) and (j) / 175.640(e) / 175.420 (a)(b), and 175.620(c). Policy number 10-PCS-001 must also be strictly adhered to. Contractor also states manways will be installed. A separate upgrade permit will be necessary to upgrade ANY other equipment for this tank system for E-85 compatibility.

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Tank Tech, Inc. 3975 State Highway H Sikeston, MO 63824	Contact Person: Rob Russell Phone: (573) 471-1932 Contractor Registration # IL-2136 Exp. 04/29/2014
---	---

Sincerely,

Jim Coffey

