



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Amended

FOR OFFICE USE ONLY

Facility # 6-010678
Permit # 00839-2013ABN
Request Rec'd 08/20/2013
Amended Date 09/16/2013
Approval Date 8/21/2013 DS
Permit Expires 2/21/2014

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Gateway Regional Medical Center 2100 Madison Avenue Granite City, IL 62040 Contact: Frank L. Hann	(2) FACILITY - name and address where tanks are located: Gateway Regional Medical Center 2100 Madison Avenue Granite City, Madison Co., IL Contact: Frank L. Hann
---	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned:* (TK # 1, 2, 3, 4) - 20,000 gallons, (TK # 5) - 5,000 gallons
 - (b) Product stored in each tank:* (TK # 1, 2, 3, 4) - Heating Oil, (TK # 5) - Diesel Fuel
 - (c) Location of tanks being abandoned:* See site plan and contingencies section
 - (d) Location of piping being abandoned:* See site plan and contingencies section
- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES:** Permit amendment was recieved due to tanks 1 & 2 being located too close in proximity to the existing structure, just as tanks 3,4 & 5 are. Tanks 1,2,3,4,5 will be filled with sand and flowable fill. The UST's are located in close proximity to the existing structure and their removal may result in loss of support to the structure. Certificate of site condition indicates no contamination. Site assessment report form is on file. Former removal permit #00838-2013REM for tanks 1 & 2 will not be executed.
- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

<u>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Ace Contracting of Illinois, Inc. 2160 Enterprise, PO Box 8375 Springfield, IL 62791	Contact Person: Ed Carr Phone: (217) 391-2474 Contractor Registration # IL-002358 Exp. 06/30/2014
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)