



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-014595
Permit # 00931-2013REM
Request Rec'd 09/17/2013
Amended Date
Approval Date 9/17/2013 JC
Permit Expires 3/17/2014

Removing piping only

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501-1500 Contact: Anthony Thomas (937) 863-7633	(2) FACILITY - name and address where tanks are located: Speedway 7616 115 North 8th Street West Dundee, Kane Co., IL Contact: Kevin Seyller (847) 428-6070
---	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 7) - 4,000 gallons
 - (b) *Description/location of piping being removed:* **See site plan and contingencies section.**
 - (c) *Product stored in each tank:* (TK # 7) - Kerosene
 - (d) *Reason of tanks being removed:* **Tank will remain existing. See contingencies section.**
 - (e) *If tank(s) is leaking, indicate IEMA incident number:*
 - (f) *Date each tank was last used:* (TK # 7)
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** Removing dispenser, island, and product piping only. The tank will remain existing. See permit #00932-2013UPG for further details. Tank #7 is converting from kerosene to E-85, and the new piping will be routed to a different dispenser location. The underground storage tank system for tank #7 must be compatible with E-85, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no.128, July 5th, 2011 Notices regarding the storage and dispensing of alternative fuels. Section 175.820 will also apply to this conversion.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Uni-Pump, Inc.
N59W14508 Bobolink Ave.
Menomonee Falls, WI 53051

Contact Person: Steve Bennett
Phone: (262) 252-3222

Contractor Registration # IL-1175 Exp. 11/15/2014

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)