



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
Facility # 1-010998
Permit # 00973-2013ENT
Request Rec'd 09/24/2013
Amended Date
Approval Date 9/25/2013 JC
Permit Expires 3/25/2014

Permit for HOTWORK / ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Illinois Toll Highway Authority 2700 Ogden Avenue, Downers Grove, IL 60515</p> <p>Contact: Tom Deldin (630) 241-6800 Ext. 3612</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>ISTHA M12 Maintenance Garage Route 26 & I-88, East West Tollway, Mile Post 54.3 Dixon, Lee Co., IL</p> <p>Contact: George Dumproff (708) 241-6800 Ext. 3612</p>
--	---

(3) ENTRY OF TANKS:

- (a) *Number and size of tanks being entered:* (TK # 4) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Product stored in each tank:* (TK # 4) - Diesel Fuel
- (d) *Reason for tanks being entered:* **See contingencies section.**
- (e) *Manway accessible at grade:* **Contractor states there is an existing manway.**

- (4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. **Contractor is cutting into the tank to install two new bungs and striker plates. Appropriate confined space entry permit is required from OSHA. Scheduling of tank penetration with our office is required, with qualified employee from the permitted contractor present to supervise this project. The Storage Tank Safety Specialist must be scheduled to be on site when the tanks are penetrated. A new bung will be installed in each tank. This work must be performed by a technician from the tank manufacturer, and the technician must possess a 40 hour OSHA card. See permit #00627-2013UPG for further information regarding recent work at this site.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108</p>	<p>Contact Person: Marc Bourgault Phone: (815) 398-6250</p> <p>Contractor Registration # IL-1890 Exp. 03/07/2014</p>

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Division File
 (Rev. - 9/10)