



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

**FOR OFFICE USE ONLY**  
 Facility # 2-023156  
 Permit # 00978-2013UPG  
 Request Rec'd 09/25/2013  
 Amended Date  
 Approval Date 9/25/2013 JC  
 Permit Expires 3/25/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          L &amp; B Business Enterprises, LLC          8060 N. Lawndale          Skokie, IL 60076          Contact: Mahmood Lakha (815) 485-1059</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          ZAM Management, Inc.          103 East Maple Street          New Lenox, Will Co., IL          Contact: Kathy Adair (815) 485-1059</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank:* (TK # 6) - E-85
- (e) *Type of leak detection being used:*  
 Tank:  
*Piping:* (TK # 6) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D to replace the existing line leak detector.
- (f) *Corrosion Protection being used:*  
 Tank:  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES: The underground storage tank system for tank #6 must be compatible with E-85, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no.128, July 5th 2011 notices regarding the storage and dispensing of alternative fuels.**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Stenstrom Petroleum Services Group          2422 Center Street          Rockford, IL 61108</p>	<p>Contact Person: Nate Meyer          Phone: (815) 398-6250          Contractor Registration # IL-1890 Exp. 03/07/2014</p>

Sincerely,

Jim Coffey

