



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**FOR OFFICE USE ONLY**

Facility # 6-009079  
Permit # 01017-2013UPG  
Request Rec'd 10/03/2013  
Amended Date  
Approval Date 10/3/2013 JC  
Permit Expires 4/3/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Midwest Petroleum Company 6760 Southwest Avenue Saint Louis, MO 63143 Contact: Mike McNutt (314) 647-5550 Ext. 313	<b>(2) FACILITY</b> - name and address where tanks are located: MPC #57 3999 Nameoki Road Granite City, Madison Co., IL Contact: Mike McNutt
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 9, 10) - 6,000 gallons, (TK # 11) - 10,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 9, 10, 11) - (Installing) Sheer Valves, (TK # 9, 10, 11) - (Installing) Flex Connector Steel under the dispensers only, (TK # 9, 10, 11) - (Installing) Dispenser Sumps containment FRP to replace the existing dispenser sumps ( new dispensers will also be installed at grade to replace the existing dispensers / islands in the same location, along with new bumper pole crash protection).
- (d) Product to be stored in each tank:* (TK # 9, 10, 11) - Gasoline
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Parker Petroleum Sales and Service Inc. 1424 South Main Street Troy, MO 63379	Contact Person: Andy Zalmanoff Phone: (636) 240-7777 Contractor Registration # IL-2154 Exp. 03/21/2014
--------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------

Sincerely,

Jim Coffey

